

SERTIFIKAT O KONTROLISANJU
INSPECTION CERTIFICATE

Broj / Number: T 2549
Strana / Page: 1/2

Na zahtev naručioca /
By the request of purchaser:

DOMING d.o.o.
Member of ROMSTAL group
Adresa Golubinačka bb 22310 Šimanovci, Srbija

preduzeto je/
set to:

kontrolisanje novog proizvoda
the new product inspection

u vezi sa Izveštajem o kontrolisanju /
in relation to Inspection report:

Broj / Number: T 2549

sa dokumentima u prilogu/
with enclosed documents:

- Prospekt proizvoda /
Catalogue pages of product;
- Dokumentacija o proizvodu /
Product documentation;
- Izveštaj o ispitivanju IMP-CGT broj T 2549, DVGW
NG-4312CT0530 / Test report by IMP-CGT No. T 2549,
DVGW NG-4312CT0530

INSTITUT "MIHAJLO PUPIN" - CENTAR ZA GASNU TEHNIKU izjavljuje da:
INSTITUTE "MIHAJLO PUPIN" - GAS TECHNIQUE CENTRE declares that:

predmet kontrolisanja /
the inspection object:

Kuglasta slavina za unutrašnje gasne instalacije
Ball valve for internal gas installations

proizveden od /
manufactured by:

Bianchi Fratelli S.p.A. - Via Valdoro,
5 - 25065 Lumezzane (BS) Italy

oznaka - tip - serija /
mark - type - series:

BIANCHI
Seriya 425 R
Seriya 435 R

kako je specificirano u Prilogu A, zadovoljava zahteve navedene u /
as specified in the Annex A, meets the requirements sa decribed in:

referentnom dokumentu /
reference document:

SRPS EN 331: 2016.

Sertifikat o kontrolisanju se izdaje na osnovu standarda SRPS ISO/IEC 17020:2012 .
The inspection certificate is issued basis on the standard SRPS ISO/IEC 17020:2012 .

Nadzor usaglašenosti predmeta kontrolisanja se obezbeđuje sa
periodičnim kontrolisanjem do dana /

Surveillance of the inspection object compliance is assured by periodical
inspection until the date:

14.05.2030.

INSTITUT
"MIHAJLO PUPIN"
CENTAR ZA
GASNU TEHNIKU
Volgina 15,
BEOGRAD SRBIJA
tel. +381 11 6772 151
fax. +381 11 6781 42
mispupin.rs

mesto, datum / place, date


Beograd, 15.05.2025.



INSTITUT MIHAJLO PUPIN
CENTAR ZA GASNU TEHNIKU/
INSTITUTE MIHAJLO PUPIN
GAS TECHNIQUE CENTRE

Kristina Petković dipl.maš.inž.

Ime, Prezime / Name, Surname



SERTIFIKAT O KONTROLISANJU
INSPECTION CERTIFICATE

Broj / Number:

T 2549

Strana / Page:

2/2

Prilog A /

Annex A

oznaka - tip - serija /

mark - type - series :

BIANCHI

Seriya 425 R

Seriya 435 R

detaljno oznaka - tip - serija / mark - type - series designation:		tehničke karakteristike / technical characteristics :			opis / description :
BIANCHI		DN	priključci / connections :	najveći radni pritisak, radna temperatura / maximum operating pressure, working temperature :	
425 R	1/2"	15	F-F	MOP 5, -20°C : +60°C	... poluga / lever handle
	3/4"	20	F-F		
	1"	25	F-F		
	1 1/4"	32	F-F		
	1 1/2"	40	F-F		
	2"	50	F-F		
435 R	3/8"	10	F-F		... leptir ručica / butterfly handle
	1/2"	15	F-F		
	3/4"	20	F-F		
	1"	25	F-F		