

SERTIFIKAT O KONTROLISANJU
INSPECTION CERTIFICATE

Broj / Number: T 2117

Strana / Page: 1/2

Na zahtev naručioca /
By the request of purchaser:

Doming d.o.o. Golubačka bb, 23310 Šimanovci

preduzeto je/
set to:

kontrolisanje postojećeg proizvoda
control an existing product

u vezi sa Izveštajem o kontrolisanju /
in relation to Inspection report.

Broj / Number: T 2117

sa dokumentima u prilogu/
with enclosed documents:

- Dokumentacija o proizvodu /
Product documentation;
- Izveštaj o ispitivanju /
Test report

INSTITUT "MIHAJLO PUPIN" - CENTAR ZA GASNU TEHNIKU izjavljuje da:
INSTITUTE "MIHAJLO PUPIN" - GAS TECHNIQUE CENTRE declares that:

predmet kontrolisanja /
the inspection object:

Talasasta metalna creva / Corrugated metal hoses

proizveden od /
manufactured by:

AYVAZ, Atatürk Sanayi Bölgesi Hadımköy Mahallesi
Mustafa İnan Caddesi No: 44 Arnavutköy –
İSTANBUL, TURSKA

oznaka - tip - serija /
mark - type - series:

MIGFLEX,
GAS HOSE MIG-GAS

kako je specificirano u Prilogu A, zadovoljava zahteve navedene u /
as specified in the Annex A, meets the requirements listed in:

referentnom dokumentu /
reference document:

SRPS EN ISO 10380:2014

Sertifikat o kontrolisanju se izdaje na osnovu standarda SRPS ISO/IEC 17020:2012 .
The inspection certificate is issued on the basis of standard SRPS ISO/IEC 17020:2012 .

Nadzor usaglašenosti predmeta kontrolisanja se obezbeđuje sa
periodičnim kontrolisanjem do dana /

26.07.2026.

Surveillance of the inspection object compliance is assured by periodical
inspection until the date:

mesto, datum / place, date:

Beograd, 26.07.2021.

izdat od / issued by:

RUKOVODIOCA CENTRA ZA GASNU TEHNIKU
GAS TECHNIQUE CENTRE MANAGER

Kristina Petković, M.Sc.M.E.

M.P.
S.P.

BEOGRAD



ATC

06-010

АКРЕДИТОВАНО
КОНТРОЛНО
ТЕЛО

SRPS ISO/IEC 17020:2012

SERTIFIKAT O KONTROLISANJU
INSPECTION CERTIFICATE

Broj / Number:

T 2117

Strana / Page:

1/2

Prilog A /**Annex A**

oznaka - tip - serija /

mark - type - series :

MIGFLEX,
GAS HOSE MIG-GAS

detaljno oznaka - tip - serija / mark - type - series specification :	tehničke karakteristike / technical characteristics :	kratak opis / short description :
MIG-GAS	TS - 40 °C /+150 °C p _{max} = 0,5 bar DN 12 – DN 25	<u>materijal/material:</u> o crevo/hose: AISI 316L; o priključci, (muški-ženski), AISI 304 / connectors, (female-male) AISI 304; <u>za/for</u> :gas 2H;

Sertifikat o kontrolisanju
Inspection certificate
INSTITUT
"MIHAJLO PUPIN"
CENTAR ZA
GASNU TEHNIKU
LABORATORIJA
 Volgina 15
 BEOGRAD
 SRBIJA
 tel: +381 11 6772 151
 fax: +381 11 6781 029
 impcgt@pupin.rs