



Sertifikat Certificate



INSTITUT
"MIHAJLO PUPIN"
CENTAR ZA
GASNU TEHNIKU
Volgina 15,
BEOGRAD SRBIJA
tel: +381 11 6772 151
fax: +381 11 6781-02
impcgt@pupin.rs

SERTIFIKAT

O PREGLEDU TIPa / Type examination

Broj / Number: T 22-1825-1-1

POJEDINAČNI PREGLED / Single examination

Strana / Page: 1 / 2

Dopuna Sertifikata T 1825-1

Na zahtev naručioca /
By the request of purchaser: ITALTHERM S.p.A. Via S. D'Acquisto, 10, 29010
Pontenure, Italija / Italy

preduzeto je/
has been undertaken: Kontrolisanje novog proizvoda /
the new product inspection

u vezi sa Izveštajem o usaglašenosti/
in relation to Inspection report:

Broj /
Number: T 22-1825-2

sa dokumentima u prilogu/
with attached documents:

- Uputstvo za korišćenje / User's manual
- Uputstvo za instaliranje / Installation instruction;
- Dokumentacija o proizvodu / Product documentation;
- Izveštaji o ispitivanju IMP CGT T1825; / Test reports
IMP CGT T 1825

INSTITUT "MIHAJLO PUPIN" - CENTAR ZA GASNU TEHNIKU izjavljuje da:
INSTITUTE "MIHAJLO PUPIN" - GAS TECHNIQUE CENTRE declares that:

predmet ocenjivanja /
subject of the inspection: GASNI KOTAO /
GAS BOILER

proizveden od /
manufactured by: ITALTHERM S.p.A. Via S. D'Acquisto, 10, 29010
Pontenure, Italija / Italy

oznaka - tip - serija /
mark - type - series: ROMSTAL HABITAT ... F

vrsta/type: B22, C12, C32
kategorija/category: II2H3P

kako je specificirano u Prilogu
A, zadovoljava zahteve
navedene u /
as specified in the Annex A, meets
the requirements listed in: Pravilnik o zahtevima za projektovanje, izradu
i ocenjivanje usaglašenosti gasnih aparata ("Sl.
gl. RS", br. 41/2015)
SRPS EN 15502-2-1:2013

Sertifikat o kontrolisanju se izdaje na osnovu standarda SRPS ISO/IEC 17020:2012 i
Rešenja Ministarstva rudarstva i energetike br. 312-01-01508/2016-05 /

The inspection certificate is issued on the basis of standard SRPS ISO/IEC 17020:2012
and the decree of the Ministry of Mining and Energy N° 312-01-01508/2016-05.

Ocenjivanje sprovedeno / Evaluation performed from 03.07.2018. ÷ 10.08.2018.

izdat od / issued by:

INSTITUT MIHAJLO PUPIN
CENTAR ZA GASNU TEHNIKU/
INSTITUTE MIHAJLO PUPIN
GAS TECHNIQUE CENTRE

mesto, datum / place, date: M.P./
S.P.

Beograd, 19.10.2022.

Kristina Petković dipl.maš.inž.

Ime, Prezime / Name, Surname





**Prilog A /
Annex A**

Broj /
Number: T 22-1825-1-1
Strana /
Page: 2 / 2

oznaka - tip - serija /
mark - type - series :

ROMSTAL HABITAT ... F

vrsta/type: B₂₂, C₁₂, C₃₂
kategorija/category: II₂H₃F

Sertifikat Certificate

detaljno oznaka - tip - serija / mark - type - series specification :	tehničke karakteristike / technical characteristics :	kratak opis / short description :
ROMSTAL HABITAT ... F		
ROMSTAL HABITAT 20F	Q _n =9,5 ÷ 21,0 kW P _n =8,1 ÷ 19,5 kW	za grejanje i pripremu tople sanitarne vode (TSV) sa ugrađenim primarnim izmenjivačem/ for heating and preparation of domestic hot water (DHW) with built-in plate heat exchanger
ROMSTAL HABITAT 25F	Q _n =10,0 ÷ 25,7 kW P _n =8,5 ÷ 24,0 kW	
ROMSTAL HABITAT 30F	Q _n =12,0 ÷ 30,0 kW P _n =10,2 ÷ 28,2 kW	
ROMSTAL HABITAT 35F	Q _n =13,6 ÷ 34,5 kW P _n =11,7 ÷ 32,4 kW	
ROMSTAL HABITAT 40F	Q _n =14,0 ÷ 39,5 kW P _n =12,0 ÷ 36,6 kW	
ROMSTAL HABITAT 20FR	Q _n =9,5 ÷ 21,0 kW P _n =8,1 ÷ 19,5 kW	- za grejanje i povezivanje na spoljni bojler za TSV/ for heating and connecting to an external drinking water storage for DHW
ROMSTAL HABITAT 25FR	Q _n =10,0 ÷ 25,7 kW P _n =8,5 ÷ 24,0 kW	
ROMSTAL HABITAT 30FR	Q _n =12,0 ÷ 30,0 kW P _n =10,2 ÷ 28,2 kW	
ROMSTAL HABITAT 35FR	Q _n =13,6 ÷ 34,5 kW P _n =11,7 ÷ 32,4 kW	
ROMSTAL HABITAT 40FR	Q _n =14,0 ÷ 39,5 kW P _n =12,0 ÷ 36,6 kW	

**Bilo kakve promene na uređaju moraju se prijaviti izdavaocu ove isprave. /
Any changes on the device must be reported to the issuer of this document**

**Definisani rok narednog pregleda je godinu dana u sklopu ocenjivanja
Deklaracija usaglašenosti sa tipom! / The deadline for the next review is one
year within the assessment of the Declaration of Conformity with the type!**



INSTITUT
"MIHAJLO PUPIN"
CENTAR ZA
GASNU TEHNIKU
Volgina 15,
BEOGRAD SRBIJA
tel: +381 11 6772 151
fax: +381 11 6781-02
impcgt@pupin.rs