



Sertifikat Certificate

SERTIFIKAT

O PREGLEDU TIPa / Type examination

Broj / Number: T 2009

POJEDINAČNI PREGLED / Single examination

Strana / Page: 1 / 2

Na zahtev naručioca /
By the request of purchaser: **ITALTHERM S.p.A. Via S. D'Acquisto, 10, 29010
Pontenure, Italija / Italy**

preduzeto je/
has been undertaken: **Kontrolisanje novog proizvoda
the new product inspection**

u vezi sa Izveštajem o usaglašenosti/
in relation to Inspection report:

Broj / Number : T 2009

sa dokumentima u prilogu/
with attached documents:

- Uputstvo za korišćenje / User's manual
- Uputstvo za instaliranje / Installation instruction;
- Dokumentacija o proizvodu / Product documentation;
- Izveštaji o ispitivanju KIWA 2002900; / Test reports
KIWA 2002900

INSTITUT "MIHAJLO PUPIN" - CENTAR ZA GASNU TEHNIKU izjavljuje da:
INSTITUTE "MIHAJLO PUPIN" - GAS TECHNIQUE CENTRE declares that:

predmet ocenjivanja /
subject of the inspection: **GASNI KOTAO /
GAS BOILER**

proizveden od /
manufactured by : **ITALTHERM S.p.A. Via S. D'Acquisto, 10, 29010
Pontenure, Italija / Italy**

oznaka - tip - serija /
mark - type - series : **ITALTHERM CITY CLASS ... C
ROMSTAL HABITAT ... C**

vrsta/type: **B_{11BS}**
kategorija/category: **II_{2H3P}**

kako je specificirano u Prilogu
A, zadovoljava zahteve
navedene u /
as specified in the Annex A, meets
the requirements listed in:

Pravilnik o zahtevima za projektovanje, izradu i
ocenjivanje usaglašenosti gasnih aparata ("Sl. gl.
RS", br. 41/2015)
SRPS EN 15502-2-2: 2016

Sertifikat o kontrolisanju se izdaje na osnovu standarda SRPS ISO/IEC 17020:2012 i
Rešenja Ministarstva rudarstva i energetike br. 312-01-01508/2016-05 /
The inspection certificate is issued on the basis of standard SRPS ISO/IEC 17020:2012
and the decree of the Ministry of Mining and Energy N^o 312-01-01508/2016-05.
Ocenjivanje sprovedeno / Evaluation performed from 25.03.2020. ÷ 15.05.2020.



INSTITUT
"MIHAJLO PUPIN"
CENTAR ZA
GASNU TEHNIKU
Volgina 15,
BEOGRAD SRBIJA
tel: +381 11 6772 151
fax: +381 11 6781-02
impcgt@pupin.rs

izdat od / issued by :

INSTITUT MIHAJLO PUPIN
CENTAR ZA GASNU TEHNIKU/
INSTITUTE MIHAJLO PUPIN
GAS TECHNIQUE CENTRE
Kristina Petković dipl.maš.inž.

mesto, datum / place, date : **M.P. /
Š.P.**

Beograd, 15.05.2020.



Ime, Prezime / Name, Surname



Sertifikat Certificate

Prilog A /
Annex A

Broj / Number:

T 2009

Strana / Page:

2 / 2

oznaka - tip - serija /
mark - type - series :

ITALTHERM CITY CLASS ... C
ROMSTAL HABITAT ... C

vrsta/type: B_{11BS}
kategorija/category: II_{2H3P}

detaljno oznaka - tip - serija / mark - type - series specification :	tehničke karakteristike / technical characteristics :	kratak opis / short description :
ITALTHERM CITY CLAS ... C ROMSTAL HABITAT ... C		
... 24	Q _n = 10,0 ÷ 25,7 kW * Q _n = 10,0 ÷ 25,7 kW ** P _n = 8,6 ÷ 23,3 kW * P _n = 8,6 ÷ 23,3 kW ** PMS=3 bar, PMW=6 bar Tmax=85°C	za grejanje i toplu sanitarnu vodu/ for heating and domestic hot water
... 28	Q _n = 12,0 ÷ 28,3 kW * Q _n = 12,3 ÷ 28,0 kW ** P _n = 10,0 ÷ 25,5 kW * P _n = 10,3 ÷ 25,2 kW ** IP X4D, NOx 3 230V, 50 Hz, 75W i 95W	

Napomene / notes:

* za / for G20;

** za / for G31 ;

Bilo kakve promene na uređaju moraju se prijaviti izdavaocu ove isprave. /
Any changes on the device must be reported to the issuer of this document

Definisani rok narednog pregleda je godinu dana u sklopu ocenjivanja
Deklaracija usaglašenosti sa tipom! / The deadline for the next review is one
year within the assessment of the Declaration of Conformity with the type!

Poslednja nadzorna poseta obavljena 19.10.2022.

The last audit was done 19.10.2022.



INSTITUT
"MIHAJLO PUPIN"
CENTAR ZA
GASNU TEHNIKU
Volgina 15,
BEOGRAD SRBIJA
tel: +381 11 6772 151
fax: +381 11 6781-02
impcgt@pupin.rs