

SKZ - Testing GmbH awards the following company

Heliroma-Plásticos S.A.
Zona Industrial EN1/IC2, km 250.5
3850-184 ALBERGARIA-A-VELHA
PORTUGAL

Production site: PORTUGAL

the right to use the **SKZ** testing and inspection mark



A 807

for the following plastic products

Pipes made of polyethylene of raised temperature resistance
PE-RT type II, Group: 1 ($\leq \varnothing$ 63 mm)

Dimensions	Application class			
	1	2	4	5
\varnothing 16 x 1.8 mm / \varnothing 17 x 2.0 mm / \varnothing 20 x 2.3 mm	8 bar	8 bar	8 bar	6 bar
\varnothing 16 x 2.0 mm	10 bar	8 bar	8 bar	8 bar
\varnothing 16 x 2.2 mm / \varnothing 20 x 2.8 mm	10 bar	10 bar	10 bar	8 bar
\varnothing 20 x 1.9 mm / \varnothing 25 x 2.3 mm / \varnothing 32 x 2.9 mm	6 bar	6 bar	6 bar	4 bar
\varnothing 20 x 2.0 mm	6 bar	6 bar	6 bar	6 bar

Trade name: ROMAPLUS (without barrier EVOH)
 ROMAPLUS EVOH (with barrier EVOH)

SKZ specification for tests and inspection **HR 3.52:2018-10**

Users of the **SKZ** mark are obliged to observe the required regulations for the production and testing of these products.

Date of initial certification: ---

Date of expiry: 26 July 2027

Würzburg, 7 September 2022/



i.V. 

Dipl.-Ing. Helmut Zanzinger
 Deputy Head of Certification Body